

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on build date?

Yes, service lines installed after 1/4/1989 are considered non-lead because this was when the state lead ban was enacted.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can water sampling or predictive modeling be used to classify unknown service lines?

Yes, but only after approval from ADEM.

Are there different templates for a CWS and NTNCWS?

No, both types of systems should use the available template.

Can service lines >2 inches be classified as non-lead?

Yes, any service line with a diameter of 2 inches or greater can be categorized as non-lead.

Can the inventory be submitted in alternative formats?

Yes. Water systems may export data from other databases using ADEM schema to upload to eDWRS. The required fields, which are slightly different from the EPA template, are highlighted in yellow on the ADEM template.

For Alabama Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Certification Form](#)
- [Service Line Inventory Instructions](#)
- [DWSRF Funding Resources](#)



POPULATION :

5,030,053

OF CWS :

503

#NTNCWS :

65

**#CWS SERVING
<10,000 POPULATION :**

378

**%CWS SERVING
<10,000 POPULATION :**

75%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

1,313,254

ESTIMATED LSLs :

91,544

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT I20WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@I20WATER.COM



120Water™