

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of 1/1/1990 can be classified as non-lead.

## How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Can service lines be classified as non-lead based on diameter?

Pipes greater than 2 inches in diameter can be classified as non-lead without additional verification.

## Can customer surveys be used to help with material classification?

ADEQ is currently not accepting customer attestation as a basis of material classification. The use of records and/or visual/physical field investigation should be used to determine the customer portion of the service line.

## What field verification methods are accepted?

Scratch/Magnet/Swab, CCTV, excavation, and water sampling.

## What are acceptable methods for predicting lead service lines?

Additional details regarding predictive methods ADEQ is accepting are available in the FAQ document linked in the resources section (question #13).

For Arizona Service Line Inventory Resources, click the links below.

- [Service line inventory website](#)
- [Service line inventory template](#)
- [Service line inventory FAQ](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**7,158,923**

**# OF CWS :**

**746**

**#NTNCWS :**

**200**

**#CWS SERVING  
<10,000 POPULATION :**

**675**

**%CWS SERVING  
<10,000 POPULATION :**

**90%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**704,894**

**# ESTIMATED LSLs :**

**11,429**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$28,650,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, [JONATHAN.CUPPETT@120WATER.COM](mailto:JONATHAN.CUPPETT@120WATER.COM)



120Water™