

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on build date?

Yes, service lines installed after 6/1/1988 are considered non-lead because this is when the state lead ban was enacted.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines >2 inches be classified as non-lead?

Yes, any service line with a diameter of 2 inches or greater can be categorized as non-lead.

Is technical assistance available to help with the inventory?

Yes, this offer is available to systems that serve populations under 50,000 and there is no cost for the service. Fill out the technical assistance form in the resources section below.

How does the inventory need to be submitted?

The template must be submitted to the Arkansas Department of Health, Engineering Section through the [Engineering's File Transfer Portal](#).

For Arkansas Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Template](#)
- [Technical Assistance Form](#)
- [DWSRF Funding Resources](#)



POPULATION :

3,013,756

OF CWS :

673

#NTNCWS :

30

**#CWS SERVING
<10,000 POPULATION :**

622

**%CWS SERVING
<10,000 POPULATION :**

92%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

1,148,503

ESTIMATED LSLs :

171,771

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$45,299,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™