

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on build date?

Yes. Service lines installed after 1/1/1986 are considered non-lead because this was when the state lead ban was enacted.

Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 4 inches or greater can be categorized as non-lead.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

What verification methods must be approved on a case-by-case basis?

Water Sampling, statistical methods, interviews, and emerging methods. Additional details on statistical methods can be found in the "SLI Methods Presentation" in the resources link below.

Can information associated with California Health and Safety Code section 116885 requirements, "Lead Service Lines in Public Water Systems," be used for the LCRR inventory?

Yes, but the LCRR inventory must also include the portion of the service line from the meter to the building inlet.

For California Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory FAQ](#)
- [Service Line Inventory Instructions](#)
- [Service Line Inventory Presentation](#)
- [Service Line Inventory Methods Presentation](#)
- [DWSRF Funding Resources](#)



POPULATION :

39,576,757

OF CWS :

2,859

#NTNCWS :

1,476

**#CWS SERVING
<10,000 POPULATION :**

2,408

**%CWS SERVING
<10,000 POPULATION :**

84%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

2,227,667

ESTIMATED LSLs :

13,476

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™