

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of January 31, 1988, can be classified as non-lead. Service lines installed between January 1, 1960 to January 31, 1988, can also be classified as non-lead if the water system has reviewed available records and there is no evidence indicating the presence of lead service lines and/or goosenecks installed after 1959.

## Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 4 inches or greater can be classified as non-lead

## How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Is there a process for determining Galvanized Requiring Replacement if Records Are Not Available?

Yes, see "Service Line Inventory Guidance" in the resources below.

## Is there a specific process for classifying service line materials?

Yes, there is a specific framework to develop and complete a service line inventory. See "Service Line Inventory Guidance" in the resources below.

## Is funding available ?

Technical assistance and grants to support eligible water systems with their service line inventory and lead service line replacement planning are available. See the Inventory Website below for details.

For Colorado Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Guidance](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**5,782,171**

**# OF CWS :**

**944**

**#NTNCWS :**

**172**

**#CWS SERVING <10,000 POPULATION :**

**852**

**%CWS SERVING <10,000 POPULATION :**

**90%**

**POPULATION SERVED BY SYSTEMS SERVICE <10,000 :**

**928,499**

**# ESTIMATED LSLs :**

**111,907**

**BIPARTISAN INFRASTRUCTURE LAW DWSRF LEAD SERVICE LINE REPLACEMENT ALLOCATION :**

**\$32,600,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™