

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of 1/1/1990 can be classified as non-lead.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines be classified as non-lead based on diameter?

Pipes greater than 2 inches in diameter can be classified as non-lead without additional verification.

Can predictive modeling be used for material classification?

Systems should consult with the State for approval prior to using predictive modeling to classify service line materials.

For Hawaii Service Line Inventory Resources, click the links below.

- [Service line inventory website](#)
- [Service line inventory template](#)
- [Service line inventory guidance](#)
- [DWSRF Funding Resources](#)



POPULATION :

1,460,137

OF CWS :

120

#NTNCWS :

15

**#CWS SERVING
<10,000 POPULATION :**

104

**%CWS SERVING
<10,000 POPULATION :**

87%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

200,651

ESTIMATED LSLs :

9,589

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™