

SERVICE LINE INVENTORY - DRAFT



When is the initial inventory due?

The INITIAL Material Inventory was required to be electronically submitted to the IEPA by April 15, 2023. The COMPLETE Material Inventory is required to be submitted no later than April 15, 2024.

What are the Illinois inventory requirements?

The Lead Service Line Replacement and Notification Act (LSLRNA) (Public Act 102-0613) replaced the former lead materials inventory requirements. The first purpose of the LSLRNA is to require owners and operators of community water supplies to develop, implement, and maintain a comprehensive water service line material inventory and replacement plan.

Can service lines be classified as non-lead based on install/build date?

Structures built after the state lead ban of January 1, 1988 can be classified as non-lead.

Can service lines be classified as non-lead based on diameter?

Pipes greater than 2 inches in diameter can be classified as non-lead without additional verification.

How are lead goosenecks being considered?

Lead goosenecks are considered a source of lead for lead service lines and galvanized requiring replacement service lines.

Can predictive modeling be used to classify service line materials?

Systems should consult with the State for approval prior to using predictive modeling to classify service line materials.

For Illinois Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Public Act 102-0613](#)
- [DWSRF Funding Resources](#)



POPULATION :

12,822,739

OF CWS :

1,754

#NTNCWS :

418

#CWS SERVING <10,000 POPULATION :

1,525

%CWS SERVING <10,000 POPULATION :

87%

POPULATION SERVED BY SYSTEMS SERVICE <10,000 :

2,322,683

ESTIMATED LSLs :

1,043,294

BIPARTISAN INFRASTRUCTURE LAW DWSRF LEAD SERVICE LINE REPLACEMENT ALLOCATION :

\$230,177,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™