

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of 3/1/1987 can be classified as non-lead.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines be classified as non-lead based on diameter?

Most lead service lines are 2 inches or less in diameter. There have been a few instances of lead service lines larger than 2 inches and water systems should conduct verifications.

Are there different templates for a Community Water system (CWS) than a Non-Transient, Non-Community Water System (NTNCWS)?

No, not at this time.

What methods (other than the required records review) are allowable to classify service line materials?

Visual inspection, water sampling, excavation, and predictive modeling can be used to classify service line materials.

For Indiana Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Guidance](#)
- [Service Line Inventory Reference Guide](#)
- [IFA Service Line Funding](#)
- [DWSRF Funding Resources](#)



POPULATION :
6,790,280

OF CWS :
778

#NTNCWS :
594

#CWS SERVING
<10,000 POPULATION :
689

%CWS SERVING
<10,000 POPULATION :
89%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
1,184,732

ESTIMATED LSLs :
265,400

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$65,161,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™