

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on build date?

Yes, homes built after 1988 (e.g., 1/1/1989) can be designated as non-lead

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be categorized as non-lead.

What verification methods are approved for classifying service line materials?

Methods and strategies used to classify service line materials must be detailed on the inventory template, and systems should have confidence in their material determination.

For Iowa Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Presentation](#)
- [Service Line Inventory Template <10,000 connections](#)
- [Service Line Inventory Template >10,000 connections](#)
- [DWSRF Funding Resources](#)



POPULATION :

3,192,406

OF CWS :

1076

#NTNCWS :

120

**#CWS SERVING
<10,000 POPULATION :**

1,027

**%CWS SERVING
<10,000 POPULATION :**

95%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

1,061,805

ESTIMATED LSLs :

96,436

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$29,319,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™