

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Is technical assistance available to help water systems complete their service line inventory?

Yes, see the "Technical Assistance" link in the resources section below.

## Are water systems allowed to excavate on private property to determine the service line material?

"Pot-holing" or hydro-excavation is one approach that may be used to identify or verify both publicly and privately owned service line materials. However, systems are not required to use excavation of any kind to identify service line materials on private property without the written consent of the property owner.

**For Kansas Service Line Inventory Resources, click the links below.**

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Guidance](#)
- [Service Line Inventory Technical Assistance Request](#)
- [DWSRF Funding Resources](#)



**POPULATION :**  
**2,940,865**

**# OF CWS :**  
**864**

**#NTNCWS :**  
**37**

**#CWS SERVING**  
**<10,000 POPULATION :**  
**831**

**%CWS SERVING**  
**<10,000 POPULATION :**  
**96%**

**POPULATION SERVED BY**  
**SYSTEMS SERVICE <10,000 :**  
**855,695**

**# ESTIMATED LSLs :**  
**54,107**

**BIPARTISAN INFRASTRUCTURE**  
**LAW DWSRF LEAD SERVICE LINE**  
**REPLACEMENT ALLOCATION :**  
**\$28,650,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™