

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Records indicating the installation date after the lead ban (the statewide ban was January 1, 1988) can be designated as non-lead.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can DOW provide feedback and guidance about the Inventory process to each water system?

Yes, systems should submit their information through the "Pre-Review" link provided in the resources section.

What verification methods are approved for classifying service line materials

See "Minimum Verification Requirements" in the Resources section for complete details.

Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be categorized as non-lead.

For Kentucky Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Start Guide](#)
- [Service Line Inventory Pre-Review](#)
- [Minimum Verification Requirements](#)
- [Predictive Modeling Resources](#)
- [DWSRF Funding Resources](#)
- [Funding Fact Sheet](#)



POPULATION :

2,940,865

OF CWS :

377

#NTNCWS :

17

**#CWS SERVING
<10,000 POPULATION :**

283

**%CWS SERVING
<10,000 POPULATION :**

75%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

1,060,235

ESTIMATED LSLs :

40,207

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™