

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Service lines installed after 1986 are unlikely to be lead and should be documented as such.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

The Maine Plumbing Code from 1926 shows a lead ban for all service lines starting at that time. Does that mean that a PWS can automatically character all service lines from homes built after that date as non-lead?

There is evidence that this lead ban was in place starting in 1926, and that is a good starting place for prioritizing further investigation at homes built before that date. However, additional documentation, such as tie card contents and local ordinances, should also be used to document service line materials.

Can predictive modeling and water sampling be used to help classify service line materials?

Consult the State before using water sampling or predictive modeling to classify service line materials.

How should brass service lines be categorized?

Brass lines can be characterized as non-lead, with a comment identifying them as brass, since brass lines are not included in the definition of lead service lines. However, brass can be a source of lead leaching into drinking water, so the PWS should document the location of brass in the distribution system and work toward removing it.

For Maine Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Template \(<25 connections\)](#)
- [Service Line Inventory FAQ](#)
- [DWSRF Funding Resources](#)



POPULATION :

1,363,582

OF CWS :

385

#NTNCWS :

382

**#CWS SERVING
<10,000 POPULATION :**

371

**%CWS SERVING
<10,000 POPULATION :**

96%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

288,852

ESTIMATED LSLs :

18,057

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™