

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, service lines installed on or after May 17, 1972, can be classified as "Non-Lead". See Table D-2 in [Appendix D](#) and [Appendix E](#) for additional details.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

What methods can be used to classify service line materials?

[Appendix D: Investigation Methods](#) contains information on material classification methods.

Can customers help to identify service line materials?

In certain situations the customer may take photographs/videos to help identify service line materials. See additional details in [Appendix D: Investigation Methods](#).

Can Interpolation or Predictive Modeling be used to classify service line materials?

Yes, see [Appendix D](#) for more information.

For Maryland Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template \(varies by system size\)](#)
- [Service Line Inventory Guidance](#)
- [Service Line Inventory Guidance Appendices A - G](#)
- [DWSRF Funding Resources](#)



POPULATION :
6,185,278

OF CWS :
470

#NTNCWS :
551

#CWS SERVING
<10,000 POPULATION :
439

%CWS SERVING
<10,000 POPULATION :
93%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
416,937

ESTIMATED LSLs :
71,166

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™