

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024. CWS are encouraged to submit their draft inventories by April 1, 2024. This would give CWS time to make sure their inventories are complete and to receive any technical assistance.

Can service lines be classified as non-lead based on install/build date?

If you have confidence that service lines in structures built after January 1, 1986, are not lead, you can classify them in the spreadsheet as "UNK-NOLG – Unknown, definitely does not contain lead or galvanized."

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement. However, MassDEP may change this in its final regulation.

Are brass service lines classified the same as lead and galvanized downstream of lead?

Brass service lines do not currently meet the EPA definition of a lead service line or galvanized service line.

Can service lines be classified as non-lead based on diameter?

Service line diameter alone should not be used to classify service lines.

Can predictive modeling be used to classify service line materials?

Yes, review the "Predictive Modeling Guidance" in the resources below for more information.

For Massachusetts Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Instructions](#)
- [Service Line Inventory FAQ](#)
- [Service Line Inventory Toolkit](#)
- [Service Line Web App Instructions](#)
- [Predictive Modeling Guidance](#)
- [DWSRF Funding Resources](#)



POPULATION :

7,033,469

OF CWS :

532

#NTNCWS :

255

**#CWS SERVING
<10,000 POPULATION :**

364

**%CWS SERVING
<10,000 POPULATION :**

68%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

713,189

ESTIMATED LSLS :

117,090

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$33,700,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™