

SERVICE LINE INVENTORY



When is the initial inventory due?

Michigan refers to its service line inventory as a "Distribution System Materials Inventory" (DSMI). A Complete DSMI (CDSMI) must be submitted by October 16, 2024. The Preliminary DSMI was due January 1, 2020.

Can service lines be classified as non-lead based on install/build date?

See the "MSLMV" in the resources section for clarification on the minimum requirements for classifying materials. Ordinances or other controls that were in place when the service line was installed specifying materials used in service line construction can be used to characterize materials as "known."

What verification methods can be used to classify service line materials?

See the "MSLMV" in the resources section for clarification on the minimum requirements for classifying materials. Recent visual verifications or ordinances/controls can be used to characterize materials as "known." The remaining "unknown" materials must be evaluated through a multi-step verification process described in the MSLMV.

How are lead goosenecks being considered?

See the "MSLMV" for more details. Unless assuming the current or previous presence of a lead gooseneck, most water supplies with galvanized service lines between the main and curb stop must physically verify the connector material.

For Michigan Service Line Inventory Resources, the links below.

- [LCR and Service Line Inventory Website](#)
- [CDSMI Overview](#)
- [CDSMI Evaluating Minimum Service Line Verification Data](#)
- [Evaluating Minimum Service Line Material Verification Webinar](#)
- [Minimum Service Line Material Verification Requirements \(MSLMV\)](#)
- [MSLMV for Manufactured Communities](#)
- [DWSRF Funding Resources](#)



POPULATION :
10,084,442

OF CWS :
1,379

#NTNCWS :
1,258

#CWS SERVING
<10,000 POPULATION :
1,241

%CWS SERVING
<10,000 POPULATION :
90%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
1,598,687

ESTIMATED LSLs :
301,790

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$72,881,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™