

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of January 1, 1985, can be classified as non-lead.

## How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Are there different templates depending on who owns the service line?

Yes, MDH has created templates for both 1) single-ownership and 2) split-ownership systems. Single ownership means that the service line is owned entirely by either the public water system or the property owner. Split ownership means that the service line is owned jointly by both the public water system and the property owner.

## What is the difference between the simple and detailed templates?

The simple templates contain the necessary information required to meet regulatory requirements. The detailed templates allow additional information to be captured for future planning purposes.

## Can service lines be classified as non-lead based on diameter?

Pipes greater than 2 inches in diameter can be classified as non-lead without additional verification.

**For Minnesota Service Line Inventory Resources, click the links below.**

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Templates and Instructions](#)
- [Service Line Inventory Guidance](#)
- [Service Line Material Definitions](#)
- [Service Line Inventory Reference Guide](#)
- [Service Line Classification Determination](#)
- [DWSRF Funding Resources](#)



**POPULATION :**  
**5,709,752**

**# OF CWS :**  
**864**

**#NTNCWS :**  
**568**

**#CWS SERVING**  
**<10,000 POPULATION :**  
**772**

**%CWS SERVING**  
**<10,000 POPULATION :**  
**89%**

**POPULATION SERVED BY**  
**SYSTEMS SERVICE <10,000 :**  
**984,422**

**# ESTIMATED LSLS :**  
**136,873**

**BIPARTISAN INFRASTRUCTURE**  
**LAW DWSRF LEAD SERVICE LINE**  
**REPLACEMENT ALLOCATION :**  
**\$37,896,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, [JONATHAN.CUPPETT@120WATER.COM](mailto:JONATHAN.CUPPETT@120WATER.COM)



120Water™