

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, systems may designate homes built after 1988 (e.g. 1/1/1989) as non-lead.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can water sampling or statistical modeling be used as a verification method?

Yes, but both methods must be approved on a case-by-case basis.

Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be classified as non-lead.

What is the difference between the "basic" and "advanced" inventory templates?

The basic templates satisfy the minimal service line inventory information collection needs. Advanced templates also collect information that can be used for other aspects of compliance.

For Mississippi Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Basic Service Line Inventory Template](#)
- [Advanced Service Line Inventory Template](#)
- [Service Line Inventory Presentation](#)
- [DWSRF Funding Resources](#)



POPULATION :

2,963,914

OF CWS :

1,023

#NTNCWS :

69

**#CWS SERVING
<10,000 POPULATION :**

966

**%CWS SERVING
<10,000 POPULATION :**

94%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

1,742,998

ESTIMATED LSLs :

11,098

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT I20WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@I20WATER.COM



120Water™