

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Maybe. The MO Lead Ban Date is 1/1/1989. Homes built after this date can be classified as non-lead, but only after 10% of the homes using the Lead Ban Date records are field verified.

What is the 10% verification requirement for records?

Historical records are allowed to be used to classify the service line material. However, Missouri requires 10% verification (ideally, field inspection) for each type of paper/digital record to support the accuracy of the record.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can predictive modeling be used to classify service line materials?

Predictive modeling can be used as a tool to help identify service line materials, but it is not an accepted identification method in the inventory template.

For Missouri Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory FAQ](#)
- [DWSRF Funding Resources](#)



POPULATION :

6,160,281

OF CWS :

1,431

#NTNCWS :

230

**#CWS SERVING
<10,000 POPULATION :**

1354

**%CWS SERVING
<10,000 POPULATION :**

95%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

1,533,840

ESTIMATED LSLs :

202,112

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$51,736,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™