

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of January 1, 1988 can be classified as non-lead.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Are there different templates for a Community Water system (CWS) than a Non-Transient, Non-Community Water System (NTNCWS)?

Yes, the NTNCWS template only requires classification for the system-owned portion of the service line.

Can predictive modeling or water sampling be used for material classification?

Predictive modeling or water sampling can be used as supporting information but can not be used to classify service line materials.

For Nebraska Service Line Inventory Resources, click the links below.

- [Service line inventory website](#)
- [Service line inventory template \(CWS\)](#)
- [Service line inventory template \(NTNCWS\)](#)
- [Service line inventory flyer](#)
- [DWSRF Funding Resources](#)



POPULATION :

1,963,333

OF CWS :

596

#NTNCWS :

138

**#CWS SERVING
<10,000 POPULATION :**

582

**%CWS SERVING
<10,000 POPULATION :**

98%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

456,484

ESTIMATED LSLs :

53,230

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™