

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Homes or other service connections with water lines installed after 9/30/1989 may be assumed to have no lead service lines, unless the PWS is aware of installations that did not comply with State law.

## Can service lines be classified as non-lead based on diameter?

Yes, pipes greater than 2 inches in diameter may be assumed non-lead regardless of construction year, unless the PWS is aware of pipes in their system that are greater than 2 inches and contain lead.

## How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Can water sampling be used to determine the service line materials? ?

Water sampling may only be used to determine a lead service line but not to determine a non-lead service line.

## Can predictive modeling be used to help classify service line materials?

Consult the State before using predictive modeling to classify service line materials. If after submittal and approval a determined non-lead service line is determined to be a lead service line, the whole method will need to be reviewed and physical verification of other non-lead service lines will be necessary.

For Nevada Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Guidance](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**3,108,462**

**# OF CWS :**

**194**

**#NTNCWS :**

**159**

**#CWS SERVING  
<10,000 POPULATION :**

**180**

**%CWS SERVING  
<10,000 POPULATION :**

**93%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**201,002**

**# ESTIMATED LSLs :**

**9,048**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$28,650,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™