

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date for the initial inventory is July 22, 2022. Annual inventories are due July 10th starting in 2023.

Can it be assumed that pipes installed after lead was banned in New Jersey in 1987, are non-lead?

No, assumptions cannot solely be made based on the date of the lead ban in NJ.

How are lead goosenecks being considered?

A lead gooseneck, or other lead fitting shall be considered to be a lead service line, regardless of the composition of the service line or other portions of piping to which such piece is attached.

How are galvanized service lines classified?

A galvanized service line shall be considered to be a lead service line.

Does this requirement apply to non-transient, non-community systems or transient, non-community systems?

This only applies to public community water systems, NOT public non-transient, non-community water systems or transient, non-community systems

Can predictive modeling be used to help classify service line materials?

Yes, there are several resources available that contain predictive modeling resources. See "Predictive Modeling Fact Sheet" as a starting point.

For New Jersey Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Template Instructions](#)
- [Service Line Inventory FAQ](#)
- [Predictive Modeling Fact Sheet](#)
- [DWSRF Funding Resources](#)



POPULATION :
9,294,493

OF CWS :
568

#NTNCWS :
653

#CWS SERVING
<10,000 POPULATION :
407

%CWS SERVING
<10,000 POPULATION :
72%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
712,804

ESTIMATED LSLs :
349,357

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$82,971,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™