

# SERVICE LINE INVENTORY Q&A



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes, systems may designate homes built after 3/1/1987 as non-lead.

## How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Can predictive modeling be used to classify service line materials?

Predictive modeling must be approved by the state prior to implementation.

## What are the differences between the inventory templates?

The templates are identical but have different numbers of rows. Systems should use the template that aligns with their number of connections.

## Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be classified as non-lead.

### For North Carolina Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template \(500 - 50,000 connections\)](#)
- [Service Line Inventory Template Instructions](#)
- [Inventory Communication Letter](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**10,453,948**

**# OF CWS :**

**1993**

**#NTNCWS :**

**327**

**#CWS SERVING  
<10,000 POPULATION :**

**1,848**

**%CWS SERVING  
<10,000 POPULATION :**

**93%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**1,474,252**

**# ESTIMATED LSLs :**

**369,715**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$87,290,000**



FOR MORE INFORMATION CONTACT I20WATER DIRECTOR OF WATER QUALITY COMPLIANCE, [JONATHAN.CUPPETT@I20WATER.COM](mailto:JONATHAN.CUPPETT@I20WATER.COM)



I20Water™