

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes. The OK Lead Ban was adopted on 5/6/1987, and local governments may have adopted a different date (e.g., earlier). Thus, water systems should check with their local government to determine the appropriate date. Structures built after the Lead Ban can be classified as non-lead.

## How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Can predictive modeling be used to classify service line materials?

Predictive modeling must be approved by the state before implementation.

## Can water sampling be used to classify service line materials?

Water quality sampling can be used together with other investigative methods but should not be used as the sole source for classification.

## Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be classified as non-lead.

**For Oklahoma Service Line Inventory Resources, click the links below.**

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Instructions](#)
- [Service Line Inventory Guidance](#)
- [Service Line Inventory Guidance \(Spanish\)](#)
- [Service Line Inventory Mailer 1](#)
- [Service Line Inventory Mailer 2](#)
- [How to Collect GPS Coordinates](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**3,963,516**

**# OF CWS :**

**895**

**#NTNCWS :**

**877**

**#CWS SERVING  
<10,000 POPULATION :**

**842**

**%CWS SERVING  
<10,000 POPULATION :**

**94%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**1,165,014**

**# ESTIMATED LSLs :**

**28,679**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$28,650,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™