

# SERVICE LINE INVENTORY Q&A



## When is the initial inventory due?

October 16, 2024

## Can stand-alone records be used to verify that a pipe is "non-lead"?

Records indicating a service line installation/replacement date after January 6, 1991 (the effective date of the PA Lead Ban) can be used as sole verification for a "non-lead" classification. Also see "Updated Non-Lead Classification Requirements" in the resources section.

## How are lead goosenecks considered for service line definitions?

A service line with only a lead gooseneck, pigtail, or connector would not be considered a lead service line. However, if a lead gooseneck is upstream of a galvanized line, the service line would be galvanized requiring replacement.

## What methods can be used to classify service line materials?

PA has specific requirements to classify service line materials. See "Sufficient Evidence for Non-Lead Designation" and "Inventory Guidance" in the resources below for complete details.

## Do lead-lined galvanized pipes exist in PA?

PA has evidence that Lead-lined galvanized pipes were installed in Scranton, Indiana, and Reading. These pipes should be treated as lead service lines.

For Pennsylvania Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Updated Non-Lead Classification Requirements](#)
- [Template Instructions](#)
- [Inventory Guidance](#)
- [Sufficient Evidence for Non-lead Designation](#)
- [Inventory FAQ](#)
- [Very Small System Resources \(<5 connections\)](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**13,011,844**

**# OF CWS :**

**1891**

**#NTNCWS :**

**1185**

**#CWS SERVING  
<10,000 POPULATION :**

**1,744**

**%CWS SERVING  
<10,000 POPULATION :**

**92%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**2,045,746**

**# ESTIMATED LSLS :**

**688,697**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$154,956,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, [JONATHAN.CUPPETT@120WATER.COM](mailto:JONATHAN.CUPPETT@120WATER.COM)



120Water™