

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement. However, in RI, all galvanized service lines are classified as lead service lines.

Does Rhode Island have a state specific regulation related to reducing Lead in drinking water?

Yes, In 2023, amendments to the Rhode Island Lead Poisoning Prevention Act (LPPA), went into effect and established additional requirements. The LCRR and LPPA focus on identifying the areas most impacted by lead in drinking water and on replacing lead service lines.

Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of 1/1/1987 can be classified as non-lead.

What methods can systems use to verify service line materials?

Records, visual inspections, and input from customers can be used. Other procedures may be available if approved by RIDOH.

Are Technical Assistance (TA) and Funding Resources available to help to complete the inventory?

Yes, TA and other funding related resources are available through the inventory website in the resources section below.

For Rhode Island Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Memo](#)
- [DWSRF Funding Resources](#)



POPULATION :
1,098,163

OF CWS :
90

#NTNCWS :
80

#CWS SERVING
<10,000 POPULATION :
75

%CWS SERVING
<10,000 POPULATION :
83%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
116,226

ESTIMATED LSLs :
75,749

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™