

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, systems may designate homes built after 12/1/1988 as non-lead.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can predictive modeling and water sampling be used to classify service line materials?

Predictive modeling and water sampling must be approved by the state before implementation.

What are the differences between the CWS and NTCWS inventory templates?

The CWS template has columns to input each portion of the service line material (e.g., public and private). The NTCWS template only has a single column to enter the service line material for the building.

Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be classified as non-lead.

For South Carolina Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [CWS Service Line Inventory Template](#)
- [NTCWS Service Line Inventory Template](#)
- [DWSRF Funding Resources](#)



POPULATION :

5,124,712

OF CWS :

574

#NTCWS :

86

**#CWS SERVING
<10,000 POPULATION :**

496

**%CWS SERVING
<10,000 POPULATION :**

86%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

753,430

ESTIMATED LSLs :

108,177

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$31,809,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™