

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the lead ban of 7/1/1988 can be classified as non-lead.

## How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Is the inventory the same as the Master Sample Site List (MSSL)?

The MSSL only contains the minimum required quantity of sites for lead and copper tap sampling plan. The inventory will contain plumbing details for ALL service connections on the distribution system.

## Can water sampling be used to classify service line materials?

Sequential sampling of the service line may be used to determine composition through lead results when visual inspection is not feasible. It may not work to determine "Non-Lead" because of corrosion control films on pipe interior, but this method could be used to determine LSL or GRR if lead is detected prior to the tap.

## Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be classified as non-lead.

For Tennessee Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory FAQ](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**6,916,897**

**# OF CWS :**

**451**

**#NTNCWS :**

**28**

**#CWS SERVING  
<10,000 POPULATION :**

**312**

**%CWS SERVING  
<10,000 POPULATION :**

**69%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**1,056,655**

**# ESTIMATED LSLS :**

**381,342**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$89,756,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™