

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes. Structures built after the lead ban on July 1, 1988, can be classified as non-lead.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can predictive modeling be used to classify service line materials?

Predictive modeling can be used as a tool to prioritize investigations. However, state approval is required if it is to be used as the sole means for material determination.

Can water sampling be used to classify service line materials?

Water quality sampling can be used with other investigative methods but should not be used as the sole source for classification.

For Texas Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Investigation SOP](#)
- [DWSRF Funding Resources](#)



POPULATION :

29,183,290

OF CWS :

4,654

#NTNCWS :

888

**#CWS SERVING
<10,000 POPULATION :**

4,271

**%CWS SERVING
<10,000 POPULATION :**

92%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

713,189

ESTIMATED LSLs :

647,640

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$146,246,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™