

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, review the "Methods Guidance" in the resources section for details on determining service line materials.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines be classified as non-lead based on diameter?

Yes, review the "Methods Guidance" in the resources section for details on determining service line materials.

Can predictive modeling be used for material classification?

Yes, review the "Methods Guidance" in the resources section for details on determining service line materials.

Is funding available to complete the service line inventory?

Yes, refer to the Financial Assistance details in the "Service Line Inventory Website".

What if my system does not have lead pipes?

Systems that can verify they have all non-lead service lines can submit a "Non-Lead Form" available in the resources section below. You will need to list the number of service lines and describe in detail the methods used to make the service line material determination.

For Utah Service Line Inventory Resources, click the links below.

- [Service line inventory website](#)
- [Service line inventory template](#)
- [Service line inventory methods guidance](#)
- [Non-lead form](#)
- [DWSRF Funding Resources](#)



POPULATION :

3,275,252

OF CWS :

505

#NTNCWS :

82

**#CWS SERVING
<10,000 POPULATION :**

438

**%CWS SERVING
<10,000 POPULATION :**

87%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

536,797

ESTIMATED LSLs :

14,293

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™